

Annual Drinking Water Quality Report for 2022
For Water Customers in the Village and Town Water Districts of:
Mt. Morris, Leicester, and Cuylerville Water Systems

Public Water System Identification Numbers

Village of Mt. Morris 2501023
Town of Mt. Morris 2500703

Village of Leicester 2501020
Town of Leicester 2501014

Issued: 4/2023

Prepared by Chris M Young: Village of Mt. Morris Water Dept.

INTRODUCTION

To comply with State regulations, The Village of Mount Morris will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, Village of Mount Morris and Village of Leicester public water systems met all State drinking water health standards. We are proud to report that these systems did not violate a maximum contaminant level or any other water quality standard. Town of Mount Morris and Town of Leicester public water systems found disinfection byproducts at levels higher than the State allows. As we told you at that time, water in these systems temporarily exceeded drinking water standards and the problems were rectified by additional flushing and operational changes. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

On November 10, 2022 valves in the Town of Leicester were opened to feed the tank on Caledonia Road with water purchased from the Town of York. The tank was previously fed by a transmission main from the Village of Leicester PWS. The Town of Leicester, including Cuylerville, is now primarily fed by water purchased from the Town of York and are now considered part of the Leicester-York PWS. The remaining service connections fed by the Village of Leicester, including Route 20A from the Village line east to Beards Creek and South Street, remain part of the Town of Leicester PWS.

If you have any questions about this report or concerning your drinking water, please feel free to contact Chris Young, Superintendent of Public Works/Operator in Responsible Charge for the Village of Mt. Morris at (585) 658-2331. Mr. Young can also supply contact numbers for the purchasing systems. You may also contact the Livingston County Health Department at (585) 243-7280. We encourage our valued customers to become informed and to feel secure concerning the state of their drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. Meetings are typically held once a month at 117 Main Street, on the third Monday of the month at 6:00 pm.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is Silver Lake in Wyoming County. During 2022, our system did not experience any restriction of our water source. A pump station near the Silver Lake outlet intermittently delivers raw water to the 5 million-gallon reservoir at the Water Treatment Plant. Although late summer algae blooms create some taste and odor removal problems, the quality of raw water is very good. Turbidities of around 1.0 NTU and pH ranges of around 8.00 are optimal for our treatment processes. Sodium Permanganate is added to the raw (untreated) water at the Lake intake to discourage algae growth and zebra mussels. Water from the reservoir then enters the treatment plant. Our treatment processes include coagulation using a solution of poly aluminum chloride hydroxide sulfate (a coagulant), clarification, mixed media filtration (anthracite, sand, garnet), corrosion control using blended

phosphates, and disinfection using sodium hypochlorite. Finished water turbidities ranged between 0.02-0.19 NTU's (nephelometric turbidity units). 100% of our turbidity readings for the year 2022 were at or below the 0.3 NTU. Acceptable free available chlorine residuals (chlorine available to kill bacteria) are maintained in the clear well (storage tank) and throughout the entire distribution systems to ensure inactivation of giardia lamblia cysts and bacteria. The treatment process is completed as water exits the 1 million gallon clear well and enters the distribution system.

The NYS Department of Health has evaluated this Public Water System's susceptibility to contamination under the Source Water Assessment Program (SWAP), their findings are summarized in the paragraph below. It is important to stress that these assessments were created using available information and only estimate the *potential* for source water contamination. Elevated susceptibility ratings *do not* mean that source water contamination has or will occur for the public water system. The Village of Mt. Morris provides treatment and regular monitoring to ensure water delivered to customers meets all applicable standards.

SWAP Executive Summary for Silver Lake:

This assessment found an elevated susceptibility to contamination for this source of drinking water. The amount of agricultural lands in the assessment area results in elevated potential for pesticide, DPB precursors, microbial and phosphorous contamination. In addition, the elevated density of CAFOs (Concentrated Animal Feeding Operations) in the assessment area very likely adds to the potential for contamination. No permitted discharges are found in the assessment area. There are no noteworthy contamination threats associated with other discrete contaminant sources. Additional sources of potential contamination include: An active railroad system and a golf course.

FACTS AND FIGURES

Our water system serves approximately 5000 people through 1732 service connections. The total water produced in 2022 was 184 million gallons. The daily average of water treated and pumped into the distribution system was 504,000 gallons per day. Our highest single day was 763,000 gallons. The amount of water delivered to customers was 151 million gallons. 6.5 million gallons were used for filter backwashes. This leaves an unaccounted for total of 15.5 million gallons. This water was used to flush mains, fight fires and leakage. (8.9% of the total amount produced).

2022, water customers were charged:

Village of Mt. Morris.

0-3,000 gal per quarter= 42.50 (Base Charge)

4,000-10,000 gal, \$2.75 per 1,000 gal.

11,000 gal and up \$3.00 per 1,000 gal.

Town of MT Morris Water District #1

0-3,000 per quarter = \$41.35 (Base Charge)

\$5.25 for each additional 1,000 gal.

Village of Leicester

0-4,000 Gal \$65.00 (Base Charge.)

\$3.95 For each additional 1,000 gal

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Livingston County Health Department at (585-2437280).

| Detected Contaminant | Violation Yes/No | Date Of Sample | Level Detected (Avg/Max) (range) | Unit measurement | MCLG | Regulatory Limit (MCL,TT, MRDL, AL) | Typical source of Contaminant |
|--|------------------|-----------------------|--|------------------|----------|---|---|
| Chlorine Residuals Measured in Distribution: Village of Mount Morris | | | | | | | |
| Chlorine Residual | No | Daily | Avg/Max 1.0/ 1.7 Range .42-1.7 | mg/l | N/A | MRDL=4.0 | Water additive used to control microbes |
| Radioactive: | | | | | | | |
| Radium 228 | no | 12/13/22 | 1.13 | pCi/l | 0pCi/l | MCL=5pCi/l | Erosion of natural deposits |
| Inorganics: | | | | | | | |
| Sodium* (see health effects language) | no | 6/14/22 | 24.0 | mg/l | N/A | No designated limits | Naturally occurring; road salt; water softeners; animal waste |
| Chloride | no | 6/14/22 | 42.0 | mg/l | N/A | MCL=250mg/l | Naturally occurring or indicative of road salt contamination. |
| Barium | no | 11/15/22 | 0.023 | mg/l | 2 mg/l | MCL=2mg/l | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| Nickel | no | 11/15/22 | 0.0014 | ug/l | N/A | N/A | N/A |
| Nitrate | no | 6/14/22 | 0.72 | mg/l | 10/mg/l | MCL=10mg/l | Runoff from fertilizer use, leaching from septic tanks, sewage, erosion of natural deposits |
| *Water containing more than 20 mg/l of sodium should not be used for drinking by people on very restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets. | | | | | | | |
| Lead and Copper: | | | | | | | |
| If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants, and young children. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. Village of Mount Morris is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at http://www.epa.gov/safewater/lead . | | | | | | | |
| Lead | no | 6/16-6/30 2020 | *0.0010 Range: <0.0010- 0.0020 | ug/l | 0 ug/l | AL=15ug/l | Corrosion of household plumbing system; erosion of natural deposits |
| Copper | no | 6/16-6/30 2020 | *0.14 Range: 0.010- 0.77 | mg/l | 1.3 mg/l | AL=1.3mg/l | Corrosion of household plumbing system; erosion of natural deposits |
| *The level presented represents the 90 th percentile of the 20 sites tested for lead and copper. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90 th percentile is equal to or greater than 90% of the lead and copper values detected at your water system(s). In this case, 20 samples were collected at your water system(s) and the 90 th percentile value was the eighteenth highest value. The action level for lead and copper were not exceeded in any of the samples collected. | | | | | | | |
| Microbiological Contaminants/Turbidity: | | | | | | | |
| *Turbidity | no | 6/17,8/12 | Max.- 0.20 Max-0.19 | NTU | N/A | <1.0 NTU (TT) ¹ | Soil runoff |
| *Turbidity | no | (6 daily) | 100% compliance 2022 | NTU | N/A | 95% of monthly samples <0.3 NTU (TT) ¹ | Soil runoff |
| *Distribution Turbidity ² | no | (daily) 8/2022 | Range 0.04-2.10 Highest Monthly avg 0.87 | NTU | N/A | MCL= 5 NTU ² | Soil runoff |

*Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement for the year occurred on 6/17,8/12 2022 (0.20NTU). State regulations require that turbidity must not exceed 1NTU and that 95% of the monthly turbidity samples collected must measure less than or equal to 0.3 NTU.

¹ A treatment technique violation occurs if more than 5% of the composite filter effluent measurements taken each month exceed the performance standard values or if the turbidity level of representative samples of the filtered water exceeds 1.0 NTU

² Five distribution turbidity samples are required at five different locations each week. Turbidity values in the distribution system may not exceed 5 NTU.

| Detected Contaminant | Violation Yes/No | Date Of Sample | Level Detected (Avg/Max) (range) | Unit measure -ment | MCLG | Regulatory Limit (MCL or TT) | Typical source of Contaminant |
|----------------------|------------------|----------------|----------------------------------|--------------------|------|------------------------------|-------------------------------|
|----------------------|------------------|----------------|----------------------------------|--------------------|------|------------------------------|-------------------------------|

Disinfection Byproduct Precursors/ Total Organic Carbon (TOC)

| | | | | | | | |
|--------------------|----|---------|-------------------------------|------|-----|-----|--------------------------------------|
| TOC : Source Water | no | monthly | Avg: 4.36 Range: (3.8-4.7) | mg/l | N/A | N/A | Naturally present in the environment |
| TOC: Entry Point | no | monthly | Avg: 2.44 Range: (2.1-3.0) | mg/l | N/A | TT | Naturally present in the environment |

* Total Organic Carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts. TOC are removed during filtration. Compliance is based on a ratio of the actual TOC removal to the required TOC removal, which is dependent on source water alkalinity. A treatment technique (TT) violation occurs if the average removal ratio is less than 1.0. The annual average removal ratio 2022 was 1.35. In June of 2022 The Village of Mt Morris did not collect a TOC Sample, resulting in a monitoring violation.

Stage 2 Disinfection Byproducts: Village of Mt. Morris

| Detected Contaminant | Violation Yes/No | Date Of Sample | Level Detected (Avg/Max) (range) | Unit measure -ment | MCLG | Regulatory Limit (MCL or MRDL) | Typical source of Contaminant |
|----------------------|------------------|----------------|----------------------------------|--------------------|------|--------------------------------|-------------------------------|
|----------------------|------------------|----------------|----------------------------------|--------------------|------|--------------------------------|-------------------------------|

| | | | | | | | |
|--|----|--|---|------|--------|-----------------|---|
| Total Trihalomethanes (TTHM) Site 1: Village Building Site 2: Wastewater Treatment Plant | no | 5/11/21 8/10/21 11/9/21 2/8/22 5/10/22 8/9/22 11/15/22 | Site 1: *Highest Avg. 63.25 Range: 46-72 Site 2: *Highest Avg. 63.5 Range: 45-75 | ug/l | 0 ug/l | MCL= 80 ug/l | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when water contains large amounts of organic matter. |
|--|----|--|---|------|--------|-----------------|---|

| | | | | | | | |
|--|----|--|--|------|--------|-----------------|---|
| Haloacetic acids (HAA-5) Site 1: Village Building Site 2: Wastewater Treatment Plant | no | 5/11/21 8/10/21 11/9/21 2/8/22 5/10/22 8/9/22 11/15/22 | Site 1: *Highest Avg. 34 Range: 16-47 Site 2: *Highest Avg. 35.5 Range: 14-46 | ug/l | 0 ug/l | MCL= 60 ug/l | By-product of drinking water disinfection needed to kill harmful organisms. |
|--|----|--|--|------|--------|-----------------|---|

*Compliance is based on annual running average. The level presented is the highest running annual average of the data collected.

Stage 2 Disinfectants and Disinfection Byproducts: Town of Leicester

| Detected Contaminant | Violation Yes/No | Date of Samples | Level Detected (Avg/Max) (range) | Unit measure -ment | MCLG | Regulatory Limit (MCL or MRDL) | Typical source of Contaminant |
|----------------------|------------------|-----------------|----------------------------------|--------------------|------|--------------------------------|-------------------------------|
|----------------------|------------------|-----------------|----------------------------------|--------------------|------|--------------------------------|-------------------------------|

| | | | | | | | |
|-----------------------------------|----|---------|-------------------|------|-----|----------|---|
| Chlorine Residual in Distribution | no | Monthly | Range (0.08-0.97) | mg/l | N/A | MRDL=4.0 | Water additive used to control microbes |
|-----------------------------------|----|---------|-------------------|------|-----|----------|---|

| | | | | | | | |
|------------------------------|----|---|--|------|--------|-----------------|---|
| Total Trihalomethanes (TTHM) | No | 5/11/21 8/10/21 11/9/21 2/8/22 5/10/22 8/9/22 11/8/22 | *Highest Avg. 57.5 Range: 56-64 | ug/l | 0 ug/l | MCL= 80 ug/l | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when water contains large amounts of organic matter. |
| Haloacetic acids (HAA-5) | no | 5/11/21 8/10/21 11/9/21 2/8/22 5/10/22 8/9/22 11/8/22 | *Highest Avg. 35 Range: 15-49 | ug/l | 0 ug/l | MCL= 60 ug/l | By-product of drinking water chlorination disinfection needed to kill harmful organisms. |

*Compliance is based on annual running average. The level presented is the highest running annual average of the data collected

Stage 2 Disinfectants and Disinfection Byproducts: Town of Mt. Morris

| Detected Contaminant | Violation Yes/No | Date of Samples | Level Detected (Avg/Max) (range) | Unit measure -ment | MCLG | Regulatory Limit (MCL or MRDL) | Typical source of Contaminant |
|-----------------------------------|------------------|---|---|--------------------|--------|--------------------------------|---|
| Chlorine Residual in Distribution | no | Monthly | Range (0.03-1.01) | mg/l | N/A | MRDL=4.0 | Water additive used to control microbes |
| Total Trihalomethanes (TTHM) | Yes | 5/4/21 8/17/21 11/9/21 2/8/22 5/17/22 8/9/22 11/15/22 | *Highest Avg. 81.25 Range: 57-92 | ug/l | 0 ug/l | MCL = 80 ug/l | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when water contains large amounts of organic matter. |
| Haloacetic acids (HAA-5) | No | 5/4/21 8/17/21 11/9/21 2/8/22 5/17/22 8/9/22 11/15/22 | *Highest Avg. 45 Range: 2.5-56 | ug/l | 0 ug/l | MCL = 60 ug/l | By-product of drinking water chlorination disinfection needed to kill harmful organisms. |

*Compliance is based on annual running average. The level presented is the highest running annual average of the data collected. The Town of Mt Morris exceeded the TTHM maximum contaminant level (MCL) in the third Quarter of 2022. - Health Effects: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Stage 2 Disinfectants and Disinfection Byproducts: Village of Leicester

| Detected Contaminant | Violation Yes/No | Date of Samples | Level Detected (Avg/Max) (range) | Unit measure -ment | MCLG | Regulatory Limit (MCL or MRDL) | Typical source of Contaminant |
|-----------------------------------|------------------|---|---|--------------------|--------|--------------------------------|---|
| Chlorine Residual in Distribution | no | Monthly | Range (0.4-1.03) | mg/l | N/A | MRDL=4.0 | Water additive used to control microbes |
| Total Trihalomethanes (TTHM) | no | 5/11/21 8/3/21 11/9/21 2/8/22 5/10/22 8/9/22 11/15/22 | *Highest Avg. 61.75 Range: 43-72 | ug/l | 0 ug/l | MCL = 80 ug/l | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when water contains large amounts of organic matter. |
| Haloacetic acids (HAA-5) | no | 5/11/21 8/3/21 11/9/21 2/8/22 5/10/22 8/9/22 11/15/22 | *Highest Avg. 39.25 Range: 16-49 | ug/l | 0 ug/l | MCL = 60 ug/l | By-product of drinking water chlorination disinfection needed to kill harmful organisms. |

*Compliance is based on the annual running average. The level presented is the highest running annual average of the data collected.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, the Village of Mount Morris, Village and Town of Leicester, had no violations. Water is tested for coliform bacteria four times per month in the Village of Mt. Morris, and once per month in each of the purchase water systems. We have learned through our testing that other contaminants have been detected, The contaminants listed in the tables are only the constituents that were above *detectable* levels of the over 100 contaminants that were monitored and tested for.

The Town of Mt. Morris Water system exceeded the maximum contaminant level for THM's in the first calendar quarter of 2022.--Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system and may have an increased risk of getting cancer. It is important to note that the sampling location for trihalomethanes represents the location where the highest levels are thought to occur, and may not be representative of the entire system.

All purchase water systems are working diligently with the Village of Mount Morris on a flushing program to maintain fresh water in the system and lower disinfection byproduct levels, including trihalomethanes and haloacetic acids.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2022, the Village of Mt. Morris did not complete all monitoring or testing for disinfection by-product precursors during the month of June, specifically total organic carbon. As stated in the table above, the annual compliance ratio was in compliance.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION FOR NON-ENGLISH SPEAKING RESIDENTS

Spanish

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

French

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

SYSTEM IMPROVEMENTS

- The Silver Lake intake structure was inspected and cleaned twice in 2022.
- A new residential water metering system is in use and meter replacements are ongoing.
- The Village of Mt. Morris and their purchase water systems coordinated flushing twice in 2022.
- The Village of Mt Morris and the Town of Mt Morris used an auto flusher in 2022 that was installed at a North Main Street hydrant in the Village and flushed 3 times per week throughout the summer months to keep water fresh and chlorine residual levels maintained. The Town of Mt Morris auto flusher was installed at the last hydrant on 408 East.
- An aeration fountain was installed at the reservoir.
- The reservoir was inspected and the intake bubbler at the reservoir and at the lake was repaired.
- The clear well was inspected and repairs were made.

- A new PH probe was installed at the water treatment plant on Sand Hill Rd.
- A new Turbidimeter was installed for filter monitoring.

CLOSING

Thank you for supporting your water department(s). We have been very successful in complying with ever increasingly stringent water quality standards. Our history of compliance and even a few taste contest victories are certainly indicative of the aesthetic quality of the water. The Mt. Morris Water Department has an open-door policy and encourages community input.

Feel free to call:

Mt. Morris Water Treatment Plant: (585) 658-2331

Village of Mt. Morris: (585) 658-4160

Town of Leicester: (585) 382-3231

Livingston County Department of Health: (585) 243-7280

Village of Leicester: (585) 382-3699

Town of Mt. Morris: (585) 658-3375